1. SYSTEM MANIFOLD CONNECTIONS ARE GROOVED. (CLASS 125/150 OR 250/300 ANSI FLANGED OPTIONAL)

250/300 ANSI FLANGED OPTIONAL)
2. IF OPTIONAL TANK IS PROVIDED, ONE FIELD CONNECTION IS REQUIRED.

3. DATA IS BASED ON FXA-700 TANK. REFER TO TANK DRAWINGS FOR DIMENSIONS AND WEIGHTS OF OTHER MODELS.
4. MAXIMUM SYSTEM PRESSURE MUST NOT EXCEED (175) (250) (300)

4. MAXIMUM SYSTEM PRESSURE MUST NOT EXCEED (175) (250) (300) PSIG OR OPTIONAL ADJACENT TANK PRESSURE RATING.
5. RIGHT HAND SYSTEM IS SHOWN. SPECIFY LEFT HAND IF REQUIRED.

5. RIGHT HAND SYSTEM IS SHOWN. SPECIFY LEFT HAND IF REQUIRED. 6. FOR DIMENSIONS AND DRY WEIGHT CHOOSE THE LARGEST HP PUMP USED IN THE SYSTEM.


7. CUSTOM DIMENSIONS ARE AVAILABLE, CONSULT FACTORY.


SYSTEM SUCTION AND DISCHARGE CONNECTIONS:

☐ GROOVED END (SHOWN)


☐ CLASS 125/150 ANSI FLANGED (NOT SHOWN)


☐ CLASS 250/300 ANSI FLANGED (NOT SHOWN)






Page 7.30.03 Rev. F







DIMENSIONS IN INCHES (APPROX.)			SYSTEM WEIGHT IN LBS. (APPROX.)		
MODEL	L	W	WITHOUT TANK	WITH TANK	
CR1s-CR5	60	48	900	1500	
CR10-CR20	60	54	1400	2000	
CR32-CR45	70	60	2300	2900	
CR64-CR90	74	68	2300	2900	

Not	for	construction	nurnoses	unless	certified
1 4 0 0		CONSTRUCTION	parpooco	armood	cortinoa.

CERTIFIED BY: \_\_\_\_\_ DATE: \_\_\_\_

TRIPLEX MULTISTAGE VERTICAL	CANARIIS CORPORATION			
WITH OPTIONAL ADJACENT OR REMOTE MOUNTED TANK	DATE: 01/05/09 SCALE: NTS www.canariis.com			