1. SYSTEM MANIFOLD CONNECTIONS ARE GROOVED. (CLASS 125/150

ANSI FLANGED OPTIONAL)
2. IF OPTIONAL TANK IS PROVIDED, ONE FIELD CONNECTION IS REQUIRED.

AND THE REQUIRED.

3. DATA IS BASED ON FXA-700 TANK. REFER TO TANK DRAWINGS FOR DIMENSIONS AND WEIGHTS OF OTHER MODELS.

4. MAXIMUM SYSTEM PRESSURE MUST NOT EXCEED 175 PSIG OR OPTIONAL ADJACENT TANK PRESSURE RATING.


5. RIGHT HAND SYSTEM IS SHOWN. SPECIFY LEFT HAND IF REQUIRED.


6. FOR DIMENSIONS AND DRY WEIGHT CHOOSE THE LARGEST HP PUMP USED IN THE SYSTEM.
7. CUSTOM DIMENSIONS ARE AVAILABLE, CONSULT FACTORY.
8. * VFD'S OVER 15 HP MAY REQUIRE 84"

SYSTEM SUCTION AND DISCHARGE CONNECTIONS:

☐ GROOVED END (SHOWN)


☐ CLASS 125/150 ANSI FLANGED (NOT SHOWN)







Page 7.20.01 VS

Rev. D







DIMENSIONS IN INCHES (APPROX.)			SYSTEM WEIGHT IN LBS.(APPROX.)		
HORSEPOWER PER PUMP	L	W	WITHOUT TANK	WITH TANK	
2-3 HORSEPOWER	46	44	1000	1600	
5-7.5 HORSEPOWER	54	50	1100	1700	
10-15 HORSEPOWER	62	58	1500	2100	
20-25 HORSEPOWER	68	64	1700	2300	

Not for	construction	purposes	unless	certified.
---------	--------------	----------	--------	------------

CERTIFIED BY: _____ DATE: __

VARIABLE SPEED DUPLEX END SUCTION WITH PRV'S	CANARIIS CORPORATION
AND OPTIONAL ADJACENT OR REMOTE MOUNTED TANK	DATE: 01/05/09 SCALE: NTS www.canariis.com