1. SYSTEM MANIFOLD CONNECTIONS ARE GROOVED. (CLASS 125/150


ANSI FLANGED OPTIONAL)
2. IF OPTIONAL TANK IS PROVIDED, ONE FIELD CONNECTION IS


2. IF OPTIONAL TANK IS PROVIDED, ONE FIELD CONNECTION IS REQUIRED.
3. DATA IS BASED ON FXA-700 TANK. REFER TO TANK DRAWINGS FOR DIMENSIONS AND WEIGHTS OF OTHER MODELS.
4. MAXIMUM SYSTEM PRESSURE MUST NOT EXCEED 175 PSIG OR OPTIONAL ADJACENT TANK PRESSURE RATING.
5. RIGHT HAND SYSTEM IS SHOWN. SPECIFY LEFT HAND IF REQUIRED.
6. FOR DIMENSIONS AND DRY WEIGHT CHOOSE THE LARGEST HP PUMP ISSED IN THE SYSTEM. USED IN THE SYSTEM.
7. CUSTOM DIMENSIONS ARE AVAILABLE, CONSULT FACTORY.

SYSTEM SUCTION AND DISCHARGE CONNECTIONS:

☐ GROOVED END (SHOWN)


☐ CLASS 125/150 ANSI FLANGED (NOT SHOWN)







Page 7.20.03 VS

Rev. D







DIMENSIONS IN INCHES (AP	NS IN INCHES (APPROX.)			SYSTEM WEIGHT IN LBS.(APPROX.)			
HORSEPOWER PER PUMP	L	W	WITHOUT TANK	WITH TANK			
2-3 HORSEPOWER	46	44	1000	1600			
5-7.5 HORSEPOWER	54	50	1100	1700			
10-15 HORSEPOWER	62	58	1500	2100			
20-25 HORSEPOWER	68	64	1700	2300			

Not for	construction	purposes	unless	certified.
---------	--------------	----------	--------	------------

CERTIFIED BY: _____ DATE: _

VARIABLE SPEED DUPLEX END SUCTION WITH CHECK VALVES	CANARIIS CORPORATION				
AND OPTIONAL REMOTE MOUNTED TANK	DATE:	01/05/09	SCALE:	NTS	www.canariis.com